

ADDENDUM TWO

DATE: May 30, 2014

TO: All Vendors

FROM: Robert Thompson/Connie Heinrichs, Buyers
State Purchasing Bureau

RE: Questions and Answers for RFP Number 4710Z1
to be opened June 10, 2014

Following are the questions submitted and answers provided for the above mentioned Request For Proposal. The questions and answers are to be considered as part of the Request For Proposal.

QUESTIONS	ANSWERS
<p>1. Question Number: 1</p> <p>RFP Section Reference: Form B</p> <p>RFP Page Number: Page 3</p> <p>Question: It is anticipated that work will be performed at multiple locations and as such mobilization and per diem expenses will impact per foot pricing. What distance or location should be used for the Model Water Well? Should the overall mileage and per diem be itemized on the cost sheet?</p>	<p>The model water well should be used to illustrate the per foot/interval pricing.</p> <p>A revised Form B cost sheet is posted with this Addendum, to provide lines for mileage (mobilization) and per diem rates.</p>
<p>2. Question Number: 2</p> <p>RFP Section Reference: Form B</p> <p>RFP Page Number: Page 3</p> <p>Question: Does the removal of the petroleum slick include disposal or does the product remain the property of the well owner?</p>	<p>The removal of a petroleum slick if encountered does require the bidder to properly dispose of the petroleum (see Section IV. C. Project Requirements).</p>

QUESTIONS	ANSWERS
<p>3. Question Number: 3</p> <p>RFP Section Reference: Form B</p> <p>RFP Page Number: Page 3</p> <p>Question: Does the Segregated Water Sampling intend to sample static water conditions of a comingled column or is pumping desired to obtain a formation sample or both?</p>	<p>The answer is both: The segregated sampling could require a static water sample of comingled water qualities or a sample from a low flow pump in a selected section of a screened opening depending on the contaminant being sampled for.</p>