

Pete Ricketts, Governor

ADDENDUM ONE, QUESTIONS and ANSWERS

Date: January 13, 2016
To: All Bidders
From: Julie Dabydeen, Buyer
State Purchasing Bureau
RE: Addendum for Invitation to Bid Number 5183 OF
to be opened January 20, 2015 at 2:00 p.m. Central Time

Questions and Answers

Following are the questions submitted and answers provided for the above-mentioned Invitation to Bid. The questions and answers are to be considered as part of the Invitation to Bid. It is the Bidder's responsibility to check the State Purchasing Bureau website for all addenda or amendments.

QUESTIONS	ANSWERS
1. Is the RTU reference in ITB 5183 a "Cooling Only" system? The data tag does not indicate a heater installed if any. Should the powered exhaust fans be included in the unit pricing or as accessories? Please confirm.	The system should not have a heater unit. If a powered exhaust fan is needed for the unit that is being bid, bidder can list pricing on the Invitation to Bid Form line # 7 Optional-Accessories as needed.

This addendum will become part of the ITB and should be acknowledged with the Invitation to Bid.