

Pete Ricketts, Governor

ADDENDUM ONE QUESTIONS and ANSWERS

Date: May 18, 2016
 To: All Bidders
 From: Julie Dabydeen, Buyer
 AS Materiel State Purchasing Bureau
 RE: Addendum for Invitation to Bid Number 5316 OF
 to be opened May 26, 2016 at 2:00 p.m. Central Time

Questions and Answers

Following are the questions submitted and answers provided for the above mentioned Invitation to Bid. The questions and answers are to be considered as part of the Invitation to Bid. It is the Bidder's responsibility to check the State Purchasing Bureau website for all addenda or amendments.

<u>Question Number</u>	<u>ITB Section Reference</u>	<u>ITB Page Number</u>	<u>Question</u>	<u>State Response</u>
1.		23	V. Invitation to Bidders – Technical Specifications 2. Technical Specification: Pre-Cast Concrete Equipment Shelter (12' x 20' x 9') C. The shelter will be equipped with an Ice Shield to cover shelter, HVAC and exhaust hood. Ice Shield must be able to withstand ice up to approximately half-inch diameter falling from 1500' tower. Question: 1. Is an ice shield required above each of the doors?	Yes

2.		24	<p>V. Invitation to Bidders – Technical Specifications</p> <p>2. Technical Specification: Pre-Cast Concrete Equipment Shelter (12' x 20' x 9')</p> <p>L. Generator consists of: 40 kW Diesel Genset w/225A Automatic Transfer Switch with 72 hour run fuel tank.</p> <p>Question:</p> <p>1. Other manufacturers have a 200 amp ATS in lieu of a 225 amp ATS, is a 200 amp acceptable?</p>	No
3.		24	<p>2. The generator will include a 72 hour minimum run time fuel tank, what are the requirements for filling the fuel tank inside the shelter?</p>	<p>The fill cap needs to be accessible through the 48" generator door. The State does not want an outside filler cap.</p>

This addendum will become part of the ITB and should be acknowledged with the Invitation to Bid.