

ADDENDUM ONE, QUESTIONS and ANSWERS

Date: 2/1/16

To: All Bidders

From: Jeff Laabs, Buyer III
Nebraska Department of Correctional Services

RE: Addendum for Request for Proposal Number 84116-O3
to be opened February 12, 2016 at 2:00 p.m. Central Time

Questions and Answers

Following are the questions submitted and answers provided for the above mentioned Request for Proposal. The questions and answers are to be considered as part of the Request for Proposal. It is the Bidder's responsibility to check the State Purchasing Bureau website for all addenda or amendments.

<u>Question Number</u>	<u>RFP Section Reference</u>	<u>RFP Page Number</u>	<u>Question</u>	<u>State Response</u>
1.			1. I want to verify that the fire alarm systems are currently being inspected at 100% on the annual (per code) & that I understood Sara that they are also inspecting the system again at 75% of all devices on the semi-annual? NFPA 72 2002 only calls for a partial inspection on the semi-annual. Obviously testing the system again at 75% on the partial/semi-annual greatly increases the costs so just wanting to clarify.	1. Yes, annual inspection shall be 100% and semi-annual shall be at 75%.
2.	4. B.	32	2. Also, Sara had mentioned that they are performing the Code required biennial smoke detector calibrations every year but on the inspection reports she provided us on Wednesday that are dated	2. Smoke detection calibrations are required once every other year starting with the initial contract year as part of this contract.

			9-15-15 & 9-16-15 it shows that the last calibrations were 2006?	
--	--	--	--	--

This addendum will become part of the proposal and should be acknowledged with the Request for Proposal.