

Buyer: Todd Dlouhy

1244 OF  
Standby Generators

Opening Date: 02/23/06

		PARTIAL AWARD				PARTIAL AWARD							
		Cummins Central Power,		Diesel Power Equipment		High Plains Power		Interstate Power		Storage Battery Systems, Inc.			
		Unit	Extended	Unit	Extended	Unit	Extended	Unit	Extended	Unit	Extended		
		Price	Price	Price	Price	Price	Price	Price	Price	Price	Price		
QTY	UoM												
1	Generator: 100kw/125kVA, 120/240 volt, 60 hert, 3 phase	1	EA	\$31,998.00	\$31,998.00	\$34,080.00	\$34,080.00	\$34,800.00	\$34,800.00	\$36,498.00	\$36,498.00	\$41,083.90	\$41,083.90
	Comments:							Single phase, estimated one year delivery					
2	Generator: 150kw/125kVA, 120/208 volt, 60 hert, single phase	1	EA	\$47,615.00	\$47,615.00	\$57,850.00	\$57,850.00	\$55,629.00	\$55,629.00	\$51,583.00	\$51,583.00	\$57,288.00	\$57,288.00
	Comments:							Three phase, estimated one year delivery					
3	Generator: 500kw/625kVA, 277/840 volt, 60 hert, 3 phase	1	EA	\$92,878.00	\$92,878.00	\$85,390.00	\$85,390.00	\$96,973.00	\$96,973.00	\$84,376.00	\$84,376.00	\$94,096.20	\$94,096.20
	Comments:							estimated 24 week delivery					
	Terms					2%, 10		net 30		net 30		0%, 30	
	Delivery					150 Days				100 days		60 days	

Upon review of the bid materials provided for 1244 OF Standby Generator bids (Valentine, Gering, and Omaha DOC) Capital Facilities makes the following determinations and requests:

1. Apparent low bid for Valentine (100kw) and the Omaha DOC (150kw) generators is Cummins Central Power. It also appears that Cummins Central Power meets or exceeds the specification.

a. Capital Facilities requests delivery clarification for the two generators. When does the vendor propose to deliver the generators?

2. Apparent low bid for the Gering (500kw) generator is Interstate Power Systems.

a. It is acceptable to Capital Facilities that this generator not be supplied with item 4.A.7.k Weak Battery Warning Function (Pre-Alarm).

b. Capital Facilities request vendor clarification on item 5.A.7.b manual operating handle and location within enclosure. Vendor shall supply shop drawings indicating cabinet type and style including orientation of handles.

c. Capital Facilities is comfortable with the vendor's service centers being located in Omaha, Nebraska and Gillette, Wyoming as the placement of the Gillette, Wyoming location is within reasonable proximity to the installation site for the is generator.

For the above justifications, and after acceptable vendor clarifications, Capital Facilities recommends award of the generators to the above vendors.