




Nebraska Dept of Corrections - Central Office Bldg 1

801 W Prospector Place, #1, Lincoln, NE 68522





Account: Nebraska Dept of Corrections - Central Office Bldg 1
Address: 801 W Prospector Place, #1, Lincoln, NE 68522

Inspection Provider:
Lead Inspector:
Assistant Inspector:
Scope: Full
Frequency: Annual

Fire Alarm Annual Inspection Summary

Result Totals

Devices	Annunciator	Door Holder	Duct Detector	Horn	Pull Station	Smoke Detector	Strobe	Tamper	Thermal/Heat Detector	Waterflow sprinkler
Passed	1	5	5	52	22	88	37	4	12	3
Mitigated	-	-	-	-	-	-	-	-	-	-
New - Passed	-	-	-	-	-	-	-	-	-	-
Failed	-	-	-	-	-	-	-	-	-	-
Removed	-	-	-	-	-	-	-	-	-	-
Not Inspected	-	-	-	-	-	-	-	-	-	-
Total	1	5	5	52	22	88	37	4	12	3

Panel Information

Type	200 - FACP
Location	Page 3
Model	Notifier 5000
Manufacturer	Notifier
Voltage	120 VAC

This inspection was performed on 2/5/2021 in accordance with applicable requirements.

Page 1 Fire Alarm Results

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
1	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:28 AM	Passed	
2	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:29 AM	Passed	
3	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:29 AM	Passed	
4	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:30 AM	Passed	
5	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:30 AM	Passed	
6	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:30 AM	Passed	
7	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:30 AM	Passed	
8	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:30 AM	Passed	
9	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:31 AM	Passed	
10	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:31 AM	Passed	
11	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:32 AM	Passed	
12	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:32 AM	Passed	
13	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:32 AM	Passed	
14	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:32 AM	Passed	
15	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:33 AM	Passed	
16	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:33 AM	Passed	
17	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:33 AM	Passed	
18	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:33 AM	Passed	
19	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:34 AM	Passed	
20	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:34 AM	Passed	
21	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:35 AM	Passed	
22	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:35 AM	Passed	
23	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:36 AM	Passed	
24	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:36 AM	Passed	
25	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:37 AM	Passed	
26	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:37 AM	Passed	
27	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:37 AM	Passed	
28	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:38 AM	Passed	
29	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:38 AM	Passed	
30	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:38 AM	Passed	
31	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:39 AM	Passed	
32	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:39 AM	Passed	
33	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:40 AM	Passed	
34	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:40 AM	Passed	
35	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:40 AM	Passed	
36	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:40 AM	Passed	
37	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:40 AM	Passed	
38	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:41 AM	Passed	
39	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:41 AM	Passed	
40	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:41 AM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
41	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:41 AM	Passed	
42	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:41 AM	Passed	
43	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:42 AM	Passed	
44	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:42 AM	Passed	
45	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:42 AM	Passed	
46	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:42 AM	Passed	
47	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:42 AM	Passed	
48	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:43 AM	Passed	
49	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:44 AM	Passed	
50	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:45 AM	Passed	
51	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:45 AM	Passed	
52	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:45 AM	Passed	
53	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:45 AM	Passed	
54	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:46 AM	Passed	
55	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:46 AM	Passed	
56	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:47 AM	Passed	
57	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:47 AM	Passed	
58	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:47 AM	Passed	
59	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:47 AM	Passed	
60	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:47 AM	Passed	
61	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:49 AM	Passed	
62	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:49 AM	Passed	
63	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:50 AM	Passed	
64	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:50 AM	Passed	
65	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:50 AM	Passed	
66	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:50 AM	Passed	
67	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:51 AM	Passed	
68	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:51 AM	Passed	
69	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:52 AM	Passed	
70	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:52 AM	Passed	
71	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:52 AM	Passed	
72	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:53 AM	Passed	
73	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:53 AM	Passed	
74	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:53 AM	Passed	
75	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:53 AM	Passed	
76	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:53 AM	Passed	
77	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:54 AM	Passed	
78	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:54 AM	Passed	
79	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:54 AM	Passed	
80	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:54 AM	Passed	
81	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:54 AM	Passed	




Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
82	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:55 AM	Passed	
83	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:55 AM	Passed	
84	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:55 AM	Passed	
85	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:55 AM	Passed	
86	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:55 AM	Passed	
87	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:55 AM	Passed	
88	Smoke Detector	TBD	NOTIFIER	FSP851 or 2WB	TBD	2/5/2021 10:56 AM	Passed	
89	Duct Detector	TBD	NOTIFIER	DNR	TBD	2/5/2021 10:56 AM	Passed	
90	Duct Detector	TBD	NOTIFIER	DNR	TBD	2/5/2021 10:56 AM	Passed	
91	Waterflow sprinkler	TBD	NOTIFIER	FMM101	TBD	2/5/2021 10:57 AM	Passed	
92	Waterflow sprinkler	TBD	NOTIFIER	FMM102	TBD	2/5/2021 10:57 AM	Passed	
93	Waterflow sprinkler	TBD	NOTIFIER	FMM103	TBD	2/5/2021 10:57 AM	Passed	
94	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:57 AM	Passed	
95	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:58 AM	Passed	
96	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:58 AM	Passed	
97	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:58 AM	Passed	
98	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:58 AM	Passed	
99	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:58 AM	Passed	
100	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:58 AM	Passed	
101	Duct Detector					2/5/2021 10:59 AM	Passed	
102	Duct Detector					2/5/2021 10:59 AM	Passed	
103	Duct Detector					2/5/2021 10:59 AM	Passed	

Page 2 Fire Alarm Results

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
1	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 10:59 AM	Passed	
2	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:03 AM	Passed	
3	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:04 AM	Passed	
4	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:04 AM	Passed	
5	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:04 AM	Passed	
6	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:04 AM	Passed	
7	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:04 AM	Passed	
8	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:05 AM	Passed	
9	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:05 AM	Passed	
10	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:05 AM	Passed	
11	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:06 AM	Passed	
12	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:06 AM	Passed	
13	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:06 AM	Passed	
14	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:06 AM	Passed	
15	Pull Station	TBD	NOTIFIER	NBG12LX	TBD	2/5/2021 11:06 AM	Passed	
16	Annunciator		NOTIFIER	LCD80	TBD	2/5/2021 11:31 AM	Passed	
17	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:06 AM	Passed	
18	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:07 AM	Passed	
19	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:07 AM	Passed	
20	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:07 AM	Passed	
21	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:07 AM	Passed	
22	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:08 AM	Passed	
23	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:08 AM	Passed	
24	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:08 AM	Passed	
25	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:08 AM	Passed	
26	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:08 AM	Passed	
27	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:09 AM	Passed	
28	Thermal/Heat Detector	TBD	NOTIFIER	FST851 or 5601P	TBD	2/5/2021 11:09 AM	Passed	
101	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:10 AM	Passed	
102	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:10 AM	Passed	
103	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:10 AM	Passed	
104	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:10 AM	Passed	
105	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:11 AM	Passed	
106	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:11 AM	Passed	
107	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:11 AM	Passed	
108	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:12 AM	Passed	
109	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:12 AM	Passed	
110	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:12 AM	Passed	
111	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:12 AM	Passed	
112	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:13 AM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
113	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:13 AM	Passed	
114	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:13 AM	Passed	
115	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:14 AM	Passed	
116	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:14 AM	Passed	
117	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:14 AM	Passed	
118	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:14 AM	Passed	
119	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:15 AM	Passed	
120	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:15 AM	Passed	
121	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:15 AM	Passed	
122	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:15 AM	Passed	
123	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:15 AM	Passed	
124	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:15 AM	Passed	
125	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:16 AM	Passed	
126	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:17 AM	Passed	
127	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:17 AM	Passed	
128	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:17 AM	Passed	
129	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:17 AM	Passed	
130	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:17 AM	Passed	
131	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:18 AM	Passed	
132	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:18 AM	Passed	
132	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:18 AM	Passed	
133	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:18 AM	Passed	
134	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:18 AM	Passed	
135	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:19 AM	Passed	
136	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:19 AM	Passed	
137	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:19 AM	Passed	
138	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:19 AM	Passed	
139	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:19 AM	Passed	
140	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:20 AM	Passed	
141	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:20 AM	Passed	
142	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:20 AM	Passed	
143	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:20 AM	Passed	
144	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:20 AM	Passed	
145	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:21 AM	Passed	
146	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:21 AM	Passed	
147	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:21 AM	Passed	
148	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:23 AM	Passed	
149	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:23 AM	Passed	
150	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:23 AM	Passed	
151	Horn	TBD	SYSTEM SENSOR	P2WL or PC2WL	TBD	2/5/2021 11:23 AM	Passed	
152	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:25 AM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
153	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:26 AM	Passed	
154	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:26 AM	Passed	
155	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:31 AM	Passed	
156	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:31 AM	Passed	
157	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:30 AM	Passed	
158	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:30 AM	Passed	
159	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:30 AM	Passed	
160	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:29 AM	Passed	
161	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:29 AM	Passed	
162	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:29 AM	Passed	
163	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:29 AM	Passed	
164	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:28 AM	Passed	
165	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:28 AM	Passed	
166	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:28 AM	Passed	
167	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:27 AM	Passed	
168	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:27 AM	Passed	
169	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:27 AM	Passed	
170	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 11:26 AM	Passed	




Page 3 Fire Alarm Results

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
1	Door Holder	TBD	FIRELITE	FM998	TBD	2/5/2021 10:25 AM	Passed	
2	Door Holder	TBD	FIRELITE	FM998	TBD	2/5/2021 10:26 AM	Passed	
3	Door Holder	TBD	FIRELITE	FM998	TBD	2/5/2021 10:27 AM	Passed	
4	Door Holder	TBD	FIRELITE	FM998	TBD	2/5/2021 10:28 AM	Passed	
5	Door Holder	TBD	FIRELITE	FM998	TBD	2/5/2021 10:27 AM	Passed	
6	Tamper	TBD	NOTIFIER	FMM101	TBD	2/5/2021 10:28 AM	Passed	
7	Tamper	TBD	NOTIFIER	FMM101	TBD	2/5/2021 10:25 AM	Passed	
8	Tamper	TBD	NOTIFIER	FMM101	TBD	2/5/2021 10:24 AM	Passed	
9	Tamper	TBD	NOTIFIER	FMM101	TBD	2/5/2021 10:24 AM	Passed	
101	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:24 AM	Passed	
102	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:24 AM	Passed	
103	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:24 AM	Passed	
104	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:23 AM	Passed	
105	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:23 AM	Passed	
106	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:23 AM	Passed	
107	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:23 AM	Passed	
108	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:23 AM	Passed	
109	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:22 AM	Passed	
110	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:22 AM	Passed	
111	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:22 AM	Passed	
112	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:22 AM	Passed	
113	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:21 AM	Passed	
114	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:21 AM	Passed	
115	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:21 AM	Passed	
116	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:21 AM	Passed	
117	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:21 AM	Passed	
118	Strobe	TBD	SYSTEM SENSOR	SCWL OR SWL	TBD	2/5/2021 10:19 AM	Passed	
200	FACP		Notifier	Notifier 5000		2/5/2021 11:31 AM	Passed	


Battery Results

Panel Number	Type	Parent Location	Position	Voltage	Result	Comments	Date
200	12V 26AH	Page 3		13,5	Passed		2/5/2021 10:05 AM
200	12V 26AH	Page 3		13,6	Passed		2/5/2021 10:05 AM



Panel Results

Number	Type	Model	Manufacturer	Location	Layout	Result	Comments	Date
16	Annunciator	LCD80	NOTIFIER	TBD	Page 2	Passed		2/5/2021 11:31 AM
200	FACP	Notifier 5000	Notifier		Page 3	Passed		2/5/2021 11:31 AM



NFPA72 2016 Testing and Inspection Form

Property: Nebraska Dept of Corrections -
Central Office Bldg 1

Inspection Date: 2/5/2021

Property Address: 801 W Prospector Place, #1
Lincoln, NE 68522

1. PROPERTY INFORMATION

Account Name or Property Name	Nebraska Dept of Corrections - Central Office Bldg 1
Shipping Street	801 W Prospector Place, #1
Shipping City	Lincoln
Shipping State/Province	NE
Shipping Zip/Postal Code	68522
Account Phone	
Main Account Email	
Authority Having Jurisdiction	
AHJ Phone Number	
Description of property	Office building
Scope of this instance of inspection	Full

2. TESTING AND MONITORING INFORMATION

Testing Organization	
Address	
Phone	
Monitoring Organization	
Address	Customer supplied
Monitoring Org Phone	customer supplied
Monitoring Org Email	
Monitoring Acct Number	Customer supplied
Phone Line one or IP	Customer supplied

Phone Line two or IP

Customer supplied

Means Of Transmission

Pots

3. DOCUMENTATION

Onsite location of the required record documents and site specific software

Is the location of documents and software indicated on the Component list and or layouts?

If the location is not indicated as YES above give description of location here

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control unit Make and Model

Notifier 5000

4.2 Software firmware revision

NA

4.3 System Power

The description Of Primary Power is included in the List of devices on Panels as well as the Disconnecting means location.

4.3.2 Secondary Power

The description of secondary power is included in the listing of devices and capacity is also included

5. AND 7. NOTIFICATIONS MADE BEFORE AND AFTER TESTING**NOTIFICATION MADE PRIOR AND AFTER TESTING**

Description	Time in Testing	Time off testing
Monitoring Org		
BLDG management		
BLDG occupants		
AHJ		
Other If applicable		

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

6.1 CONTROL UNIT AND RELATED EQUIPMENT

Description	Visual Inspection	Functional test	Comments
Control unit	✓	✓	
Lamps/LEDs/LCDs	✓	✓	
Fuses	✓	✓	
Trouble signals	✓	✓	
Disconnect switches	✓	✓	
Ground-fault monitoring	✓	✓	
Supervision	✓	✓	
Local annunciator	✓	✓	
Remote annunciators			
Remote power panels	✓	✓	

6.2 SECONDARY POWER

6.2 Secondary Power

Description	Visual Inspection	Functional test	Comments
Battery Condition	✓	✓	
Load voltage	✓	✓	
Discharge test	✓	✓	
Charger test	✓	✓	
Remote panel batteries	✓	✓	

6.3 Alarm And Supervisory Alarm Initiating Device

Attach supplementary device test sheets for all initiating devices.

6.4 Notification Appliances

Attach supplementary appliance test sheets for all notification appliances.

6.5 Interface Equipment

Attach supplementary interface component test sheets for all interface components. Circuit Interface / Signaling Line Circuit Interface / Fire Alarm Control Interface

6.6 SUPERVISING STATION MONITORING

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	✓			
Alarm restoration	✓			
Trouble signal	✓			
Trouble restoration	✓			
Supervisory signal	✓			
Supervisory restoration	✓			

6.7 PUBLIC EMERGENCY ALARM REPORTING SYSTEM

6.7 Public Emergency Alarm Reporting System

Description	Yes	No	Time	Comments
Alarm signal				NA
Alarm restoration				NA
Trouble signal				NA
Trouble restoration				NA
Supervisory signal				NA
Supervisory restoration				NA

8. SYSTEM RESTORED TO NORMAL OPERATION

8. SYSTEM RESTORED TO NORMAL OPERATION

Date and time Restored to Normal operation.

9. CERTIFICATION

This system as specified herein has been inspected and tested according to NFPA 72, 2016 edition, Chapter 14.

Inspector Name

Date/Time

Inspector Qualifications

Phone

Company Name

10 .DEFECTS OR MALFUNCTIONS NOT CORRECTED ARE LISTED ON THE DEFICIENCIES PAGE OF THIS REPORT

10.1 ACCEPTANCE BY OWNER OR OWNER'S REPRESENTATIVE:

The listed name below accepted the test report as specified herein:

Property Rep Auto Field

If the Auto Field is not correct who is the responsible party who is accepting the Test report?

Title:

Phone:

Date:

