


2021 INSPECTION

Nebraska Correctional Youth Facility

2610 North 20th Street East, omaha, ne 68124



Account: Nebraska Correctional Youth Facility
Address: 2610 North 20th Street East, omaha, ne 68124

Inspection Provider: [REDACTED]
Lead Inspector: [REDACTED]
Assistant Inspector:
Scope: Full
Frequency:
Account Manager: [REDACTED]

Fire Alarm Inspection Summary

Result Totals

Devices	Duct Detector	Horn	Horn Strobe	Pull Station	Smoke Detector	Strobe
Passed	5	1	33	23	145	40
Mitigated	-	-	-	-	-	-
New - Passed	-	-	-	-	-	-
Failed	-	-	-	-	-	-
Removed	-	-	-	-	-	-
Not Inspected	-	-	-	-	-	-
Total	5	1	33	23	145	40

Panel Information

Type	200 - FACP
Location	1st Floor control center
Model	AFP-400
Manufacturer	Notifier
Voltage	120v

This inspection was performed on 4/8/2021 in accordance with applicable requirements.

1st Floor Fire Alarm Results

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
1	Pull Station	M107	notifier	nbg	admin NE exit	4/9/2021 1:13 PM	Passed	
2	Pull Station	M108	notifier	nbg	admin front entry	4/9/2021 1:13 PM	Passed	
3	Pull Station	M109	notifier	nbg	admin visitors hall exit	4/9/2021 1:13 PM	Passed	
4	Pull Station	M110	notifier	nbg	admin dining hall exit	4/9/2021 1:13 PM	Passed	
5	Pull Station	M111	notifier	nbg	sally north exit	4/9/2021 1:13 PM	Passed	
6	Pull Station	M113	notifier	nbg	ED east exit	4/9/2021 1:13 PM	Passed	
7	Pull Station	M114	notifier	nbg	ED nurse station	4/9/2021 1:13 PM	Passed	
8	Pull Station	M115	notifier	nbg	ED North exit	4/9/2021 1:12 PM	Passed	
9	Pull Station	M116	notifier	nbg	Gym NW exit	4/9/2021 1:12 PM	Passed	
10	Pull Station	M201	notifier	nbg	SMU day rm	4/9/2021 1:12 PM	Passed	
11	Pull Station	M202	notifier	nbg	HU1 day rm	4/9/2021 1:12 PM	Passed	
12	Pull Station	M203	notifier	nbg	HU1 day rm B	4/9/2021 1:12 PM	Passed	
13	Pull Station	M204	notifier	nbg	HU1 day rm A	4/9/2021 1:11 PM	Passed	
14	Pull Station	M213	notifier	nbg	SMU day rm A	4/9/2021 1:11 PM	Passed	
15	Pull Station	M214	notifier	nbg	SMU guard station	4/9/2021 1:11 PM	Passed	
16	Pull Station	M215	notifier	nbg	SMU Day rm B	4/9/2021 1:11 PM	Passed	
17	Pull Station	M216	notifier	nbg	HU2 Day rm A	4/9/2021 1:11 PM	Passed	
18	Pull Station	M217	notifier	nbg	HU2 Day rm B	4/9/2021 1:11 PM	Passed	
19	Pull Station	M218	notifier	nbg	HU2 Ground station	4/9/2021 1:11 PM	Passed	
20	Pull Station	M219	notifier	nbg	HU2 Day rm C	4/9/2021 1:10 PM	Passed	
21	Pull Station	M220	notifier	nbg	HU1 Penthouse	4/9/2021 1:10 PM	Passed	
22	Pull Station	M223	notifier	nbg	SMU Penthouse	4/9/2021 1:09 PM	Passed	
23	Pull Station	M226	notifier	nbg	HU2 Penthouse	4/9/2021 1:09 PM	Passed	
24	Smoke Detector	D101			By Rm A109	4/9/2021 1:09 PM	Passed	
25	Smoke Detector	D102			By Rm A113	4/9/2021 1:09 PM	Passed	
26	Smoke Detector	D103			By Rm A116	4/9/2021 1:09 PM	Passed	
27	Smoke Detector	D104			Visitors Lockers	4/9/2021 1:08 PM	Passed	
28	Smoke Detector	D105			Entry	4/9/2021 1:08 PM	Passed	
29	Smoke Detector	D106			Lobby	4/9/2021 1:07 PM	Passed	
30	Smoke Detector	D107			Security Vestibule	4/9/2021 1:07 PM	Passed	
31	Smoke Detector	D108			Vistas Hall by A142	4/9/2021 1:06 PM	Passed	
32	Smoke Detector	D109			Admin Hall by A138	4/9/2021 1:06 PM	Passed	
33	Smoke Detector	D110			Dining Hall by A140	4/9/2021 1:06 PM	Passed	
34	Smoke Detector	D111			Dining Hall by A140	4/9/2021 1:06 PM	Passed	
35	Smoke Detector	D112			Visiting Hall by A130	4/9/2021 1:06 PM	Passed	
36	Smoke Detector	D113			Visiting Hall by A130	4/9/2021 1:06 PM	Passed	
37	Smoke Detector	D114			Hall by A193	4/9/2021 1:06 PM	Passed	
38	Smoke Detector	D115			Intake Closet	4/9/2021 1:06 PM	Passed	
39	Smoke Detector	D116			Laundry Hall A176	4/9/2021 1:05 PM	Passed	
40	Smoke Detector	D117			Laundry Hall A172	4/9/2021 1:05 PM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
41	Smoke Detector	D118			Maintenance By A171A	4/9/2021 1:05 PM	Passed	
42	Smoke Detector	D123			ED Commons	4/9/2021 1:05 PM	Passed	
43	Smoke Detector	D124			ED Commons by E102	4/9/2021 1:05 PM	Passed	
44	Smoke Detector	D125			ED Hall by RR	4/9/2021 1:05 PM	Passed	
45	Smoke Detector	D126			ED Hall by E114	4/9/2021 1:05 PM	Passed	
46	Smoke Detector	D127			ED Hall by E109	4/9/2021 1:05 PM	Passed	
47	Smoke Detector	D129			ED Hall	4/9/2021 1:05 PM	Passed	
48	Smoke Detector	D130			ED Hall by E124	4/9/2021 1:04 PM	Passed	
49	Smoke Detector	D131			ED Hall by E119	4/9/2021 1:04 PM	Passed	
50	Smoke Detector	D132			Gym Back Hall	4/9/2021 12:59 PM	Passed	
51	Smoke Detector	D133			Gym Back Hall	4/9/2021 12:59 PM	Passed	
52	Smoke Detector	D201			HUI A Wing Cell A1	4/9/2021 12:59 PM	Passed	
53	Smoke Detector	D202			HUI A Wing Cell A2	4/9/2021 12:58 PM	Passed	
54	Smoke Detector	D203			HUI A Wing Cell A3	4/9/2021 12:58 PM	Passed	
55	Smoke Detector	D204			HUI A Wing Cell A4	4/9/2021 12:58 PM	Passed	
56	Smoke Detector	D205			HUI A Wing Cell A5	4/9/2021 12:58 PM	Passed	
57	Smoke Detector	D206			HUI A Wing Cell A6	4/9/2021 12:58 PM	Passed	
58	Smoke Detector	D207			HUI A Wing Cell A7	4/9/2021 12:58 PM	Passed	
59	Smoke Detector	D208			HUI A Wing Cell A8	4/9/2021 12:57 PM	Passed	
60	Smoke Detector	D209			HUI A Wing Cell A9	4/9/2021 12:57 PM	Passed	
61	Smoke Detector	D210			HUI A Wing Cell A10	4/9/2021 12:57 PM	Passed	
62	Smoke Detector	D211			HUI B Wing Cell B11	4/9/2021 12:57 PM	Passed	
63	Smoke Detector	D212			HUI B Wing Cell B12	4/9/2021 12:56 PM	Passed	
64	Smoke Detector	D213			HUI B Wing Cell B13	4/9/2021 12:56 PM	Passed	
65	Smoke Detector	D214			HUI B Wing Cell B14	4/9/2021 12:56 PM	Passed	
66	Smoke Detector	D215			HUI B Wing Cell B15	4/9/2021 12:56 PM	Passed	
67	Smoke Detector	D216			HUI B Wing Cell B16	4/9/2021 12:56 PM	Passed	
68	Smoke Detector	D217			HUI B Wing Cell B17	4/9/2021 12:56 PM	Passed	
69	Smoke Detector	D218			HUI B Wing Cell B18	4/9/2021 12:55 PM	Passed	
70	Smoke Detector	D219			HUI B Wing Cell B19	4/9/2021 12:55 PM	Passed	
71	Smoke Detector	D220			HUI B Wing Cell B20	4/9/2021 12:55 PM	Passed	
72	Smoke Detector	D221			HUI C Wing Cell C21	4/9/2021 12:55 PM	Passed	
73	Smoke Detector	D222			HUI C Wing Cell C22	4/9/2021 12:55 PM	Passed	
74	Smoke Detector	D223			HUI C Wing Cell C23	4/9/2021 12:54 PM	Passed	
75	Smoke Detector	D224			HUI C Wing Cell C24	4/9/2021 12:54 PM	Passed	
76	Smoke Detector	D225			HUI C Wing Cell C25	4/9/2021 12:54 PM	Passed	
77	Smoke Detector	D226			HUI C Wing Cell C26	4/9/2021 12:54 PM	Passed	
78	Smoke Detector	D227			HUI C Wing Cell C27	4/9/2021 12:54 PM	Passed	
79	Smoke Detector	D228			HUI C Wing Cell C28	4/9/2021 12:53 PM	Passed	
80	Smoke Detector	D229			HUI C Wing Cell C29	4/9/2021 12:53 PM	Passed	
81	Smoke Detector	D230			HUI C Wing Cell C30	4/9/2021 12:53 PM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
82	Smoke Detector	D231			SMU A Wing Cell A1	4/9/2021 12:53 PM	Passed	
83	Smoke Detector	D232			SMU A Wing Cell A2	4/9/2021 12:52 PM	Passed	
84	Smoke Detector	D233			SMU A Wing Cell A3	4/9/2021 12:52 PM	Passed	
85	Smoke Detector	D234			SMU A Wing Cell A4	4/9/2021 12:52 PM	Passed	
86	Smoke Detector	D235			SMU A Wing Cell A5	4/9/2021 12:52 PM	Passed	
87	Smoke Detector	D236			SMU A Wing Cell A6	4/9/2021 12:52 PM	Passed	
88	Smoke Detector	D237			SMU A Wing Cell A7	4/9/2021 12:52 PM	Passed	
89	Smoke Detector	D238			SMU A Wing Cell A8	4/9/2021 12:51 PM	Passed	
90	Smoke Detector	D239			SMU Entry East	4/9/2021 12:51 PM	Passed	
91	Smoke Detector	D240			SMU Entry West	4/9/2021 12:51 PM	Passed	
92	Smoke Detector	D241			SMU B Wing Cell B9	4/9/2021 12:51 PM	Passed	
93	Smoke Detector	D242			SMU B Wing Cell B10	4/9/2021 12:50 PM	Passed	
94	Smoke Detector	D243			SMU B Wing Cell B11	4/9/2021 12:50 PM	Passed	
95	Smoke Detector	D244			SMU B Wing Cell B12	4/9/2021 12:50 PM	Passed	
96	Smoke Detector	D245			SMU B Wing Cell B13	4/9/2021 12:50 PM	Passed	
97	Smoke Detector	D246			SMU B Wing Cell B14	4/9/2021 12:50 PM	Passed	
98	Smoke Detector	D247			SMU B Wing Cell B15	4/9/2021 12:49 PM	Passed	
99	Smoke Detector	D248			SMU B Wing Cell B16	4/9/2021 12:49 PM	Passed	
100	Smoke Detector	D249			HUI Entry West	4/9/2021 12:49 PM	Passed	
101	Smoke Detector	D250			HUI Spike East	4/9/2021 12:49 PM	Passed	
102	Smoke Detector	D251			HUI Spike West	4/9/2021 12:48 PM	Passed	
103	Smoke Detector	D252			SMU Entry East	4/9/2021 12:48 PM	Passed	
104	Smoke Detector	D253			SMU Entry West	4/9/2021 12:48 PM	Passed	
105	Smoke Detector	D254			HU2 Spine East	4/9/2021 12:48 PM	Passed	
106	Smoke Detector	D255			HU2 Spine West	4/9/2021 12:48 PM	Passed	
107	Smoke Detector	D256			HU2 Entry Way	4/9/2021 12:48 PM	Passed	
108	Smoke Detector	D257			HU2 A Wing Cell A1	4/9/2021 12:48 PM	Passed	
109	Smoke Detector	D258			HU2 A Wing Cell A2	4/9/2021 12:48 PM	Passed	
110	Smoke Detector	D259			HU2 A Wing Cell A3	4/9/2021 12:48 PM	Passed	
200	FACP		Notifier	AFP-400	control center	4/9/2021 1:35 PM	Passed	

Notification Fire Alarm Results

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
1	Horn Strobe		System Sensor			4/9/2021 1:35 PM	Passed	
2	Horn Strobe		System Sensor			4/9/2021 1:35 PM	Passed	
3	Horn Strobe		System Sensor			4/9/2021 1:35 PM	Passed	
4	Horn Strobe		System Sensor			4/9/2021 1:35 PM	Passed	
5	Horn Strobe		System Sensor			4/9/2021 1:35 PM	Passed	
6	Horn Strobe		System Sensor			4/9/2021 1:35 PM	Passed	
7	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
8	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
9	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
10	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
11	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
12	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
13	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
14	Horn Strobe		System Sensor			4/9/2021 1:34 PM	Passed	
15	Horn Strobe		System Sensor			4/9/2021 1:33 PM	Passed	
16	Horn Strobe		System Sensor			4/9/2021 1:33 PM	Passed	
17	Horn Strobe		System Sensor			4/9/2021 1:33 PM	Passed	
18	Horn Strobe		System Sensor			4/9/2021 1:33 PM	Passed	
19	Horn Strobe		System Sensor			4/9/2021 1:33 PM	Passed	
20	Horn Strobe		System Sensor			4/9/2021 1:33 PM	Passed	
21	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
22	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
23	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
24	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
25	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
26	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
27	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
28	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
29	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
30	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
31	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
32	Horn Strobe		System Sensor			4/9/2021 1:32 PM	Passed	
33	Horn Strobe		System Sensor			4/9/2021 1:31 PM	Passed	
34	Strobe					4/9/2021 1:31 PM	Passed	
35	Strobe					4/9/2021 1:31 PM	Passed	
36	Strobe					4/9/2021 1:31 PM	Passed	
37	Strobe					4/9/2021 1:31 PM	Passed	
38	Strobe					4/9/2021 1:31 PM	Passed	
39	Strobe					4/9/2021 1:31 PM	Passed	
40	Strobe					4/9/2021 1:31 PM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
41	Strobe					4/9/2021 1:31 PM	Passed	
42	Strobe					4/9/2021 1:31 PM	Passed	
43	Strobe					4/9/2021 1:30 PM	Passed	
44	Strobe					4/9/2021 1:30 PM	Passed	
45	Strobe					4/9/2021 1:30 PM	Passed	
46	Strobe					4/9/2021 1:30 PM	Passed	
47	Strobe					4/9/2021 1:30 PM	Passed	
48	Strobe					4/9/2021 1:30 PM	Passed	
49	Strobe					4/9/2021 1:30 PM	Passed	
50	Strobe					4/9/2021 1:30 PM	Passed	
51	Strobe					4/9/2021 1:30 PM	Passed	
52	Strobe					4/9/2021 1:30 PM	Passed	
53	Strobe					4/9/2021 1:29 PM	Passed	
54	Strobe					4/9/2021 1:29 PM	Passed	
55	Strobe					4/9/2021 1:29 PM	Passed	
56	Strobe					4/9/2021 1:29 PM	Passed	
57	Strobe					4/9/2021 1:29 PM	Passed	
58	Strobe					4/9/2021 1:29 PM	Passed	
59	Strobe					4/9/2021 1:28 PM	Passed	
60	Strobe					4/9/2021 1:28 PM	Passed	
61	Strobe					4/9/2021 1:28 PM	Passed	
62	Strobe					4/9/2021 1:28 PM	Passed	
63	Strobe					4/9/2021 1:28 PM	Passed	
64	Strobe					4/9/2021 1:28 PM	Passed	
65	Strobe					4/9/2021 1:28 PM	Passed	
66	Strobe					4/9/2021 1:27 PM	Passed	
67	Strobe					4/9/2021 1:27 PM	Passed	
68	Strobe					4/9/2021 1:27 PM	Passed	
69	Strobe					4/9/2021 1:27 PM	Passed	
70	Strobe					4/9/2021 1:26 PM	Passed	
71	Strobe					4/9/2021 1:26 PM	Passed	
72	Strobe					4/9/2021 1:26 PM	Passed	
73	Strobe					4/9/2021 1:26 PM	Passed	
74	Horn				Outside mech room	4/9/2021 1:26 PM	Passed	Square red horn

1st floor continued Fire Alarm Results

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
1	Smoke Detector	D260	Notifier	FSP751	HU2 A Wing cell A4	4/9/2021 1:26 PM	Passed	
2	Smoke Detector	D261	Notifier	FSP751	HU2 A Wing cell A5	4/9/2021 1:25 PM	Passed	
3	Smoke Detector	D262	Notifier	FSP751	HU2 A Wing cell A6	4/9/2021 1:25 PM	Passed	
4	Smoke Detector	D263	Notifier	FSP751	HU2 A Wing cell A7	4/9/2021 1:25 PM	Passed	
5	Smoke Detector	D264	Notifier	FSP751	HU2 A Wing cell A8	4/9/2021 1:25 PM	Passed	
6	Smoke Detector	D265	Notifier	FSP751	HU2 A Wing cell A9	4/9/2021 1:25 PM	Passed	
7	Smoke Detector	D266	Notifier	FSP751	HU2 A Wing cell A10	4/9/2021 1:24 PM	Passed	
8	Smoke Detector	D267	Notifier	FSP751	HU2 B Wing cell B11	4/9/2021 1:24 PM	Passed	
9	Smoke Detector	D268	Notifier	FSP751	HU2 B Wing cell B12	4/9/2021 1:24 PM	Passed	
10	Smoke Detector	D269	Notifier	FSP751	HU2 B Wing cell B13	4/9/2021 1:24 PM	Passed	
11	Smoke Detector	D270	Notifier	FSP751	HU2 B Wing cell B14	4/9/2021 1:24 PM	Passed	
12	Smoke Detector	D271	Notifier	FSP751	HU2 B Wing cell B15	4/9/2021 1:24 PM	Passed	
13	Smoke Detector	D272	Notifier	FSP751	HU2 B Wing cell B16	4/9/2021 1:24 PM	Passed	
14	Smoke Detector	D273	Notifier	FSP751	HU2 B Wing cell B17	4/9/2021 1:24 PM	Passed	
15	Smoke Detector	D274	Notifier	FSP751	HU2 B Wing cell B18	4/9/2021 1:23 PM	Passed	
16	Smoke Detector	D275	Notifier	FSP751	HU2 B Wing cell B19	4/9/2021 1:23 PM	Passed	
17	Smoke Detector	D276	Notifier	FSP751	HU2 B Wing cell B20	4/9/2021 1:23 PM	Passed	
18	Smoke Detector	D277	Notifier	FSP751	HU2 C Wing cell C21	4/9/2021 1:23 PM	Passed	
19	Smoke Detector	D278	Notifier	FSP751	HU2 C Wing cell C22	4/9/2021 1:23 PM	Passed	
20	Smoke Detector	D279	Notifier	FSP751	HU2 C Wing cell C23	4/9/2021 1:23 PM	Passed	
21	Smoke Detector	D280	Notifier	FSP751	HU2 C Wing cell C24	4/9/2021 1:23 PM	Passed	
22	Smoke Detector	D281	Notifier	FSP751	HU2 C Wing cell C25	4/9/2021 1:23 PM	Passed	
23	Smoke Detector	D282	Notifier	FSP751	HU2 C Wing cell C26	4/9/2021 1:23 PM	Passed	
24	Smoke Detector	D283	Notifier	FSP751	HU2 C Wing cell C27	4/9/2021 1:23 PM	Passed	
25	Smoke Detector	D284	Notifier	FSP751	HU2 C Wing cell C28	4/9/2021 1:22 PM	Passed	
26	Smoke Detector	D285	Notifier	FSP751	HU2 C Wing cell C29	4/9/2021 1:22 PM	Passed	
27	Smoke Detector	D286	Notifier	FSP751	HU2 C Wing cell C30	4/9/2021 1:22 PM	Passed	
28	Duct Detector	D119			Admin Mech Room AHU 1	4/9/2021 1:22 PM	Passed	
29	Duct Detector	D120			Admin Mech Room AHU 2	4/9/2021 1:22 PM	Passed	
30	Duct Detector	D287			HU1 Penthouse	4/9/2021 1:22 PM	Passed	
31	Duct Detector	D288			SMU Penthouse	4/9/2021 1:22 PM	Passed	
32	Duct Detector	D289			HU2 Penthouse	4/9/2021 1:22 PM	Passed	
33	Smoke Detector	D113	Notifier	FSP751	Visiting Hall By A130	4/9/2021 1:21 PM	Passed	
34	Smoke Detector	D114	Notifier	FSP751	By A139	4/9/2021 1:21 PM	Passed	
35	Smoke Detector	D115	Notifier	FSP751	Intake Closet	4/9/2021 1:21 PM	Passed	
36	Smoke Detector	D116	Notifier	FSP751	Laundry Hall	4/9/2021 1:21 PM	Passed	
37	Smoke Detector	D117	Notifier	FSP751	Laundry Hall	4/9/2021 1:21 PM	Passed	
38	Smoke Detector	D118	Notifier	FSP751	Maintenance By A171A	4/9/2021 1:21 PM	Passed	
39	Smoke Detector	D123	Notifier	FSP751	Ed Commons	4/9/2021 1:21 PM	Passed	
40	Smoke Detector	D124	Notifier	FSP751	ED Commons by E102	4/9/2021 1:21 PM	Passed	

Number	Type	Zone/Address	Manufacturer	Model	Location	Date	Result	Comments
41	Smoke Detector	D125	Notifier	FSP751	ED Hallway by RR	4/9/2021 1:20 PM	Passed	
42	Smoke Detector	D126	Notifier	FSP751	ED Hallway by E114	4/9/2021 1:19 PM	Passed	
43	Smoke Detector	D127	Notifier	FSP751	ED Hallway by E109	4/9/2021 1:19 PM	Passed	
44	Smoke Detector	D129	Notifier	FSP751	ED Hallway	4/9/2021 1:18 PM	Passed	
45	Smoke Detector	D130	Notifier	FSP751	ED Hallway by E124	4/9/2021 1:18 PM	Passed	
46	Smoke Detector	D131	Notifier	FSP751	ED Hallway by E119	4/9/2021 1:18 PM	Passed	
47	Smoke Detector	D132	Notifier	FSP751	Gym Back Hallway	4/9/2021 1:17 PM	Passed	
48	Smoke Detector	D133	Notifier	FSP751	Gym Back Hallway	4/9/2021 1:17 PM	Passed	
49	Smoke Detector	D201	Notifier	FSP751	HU1 A Wing Cell A1	4/9/2021 1:17 PM	Passed	
50	Smoke Detector	D202	Notifier	FSP751	HU1 A Wing Cell A2	4/9/2021 1:17 PM	Passed	
51	Smoke Detector	D203	Notifier	FSP751	HU1 A Wing Cell A3	4/9/2021 1:17 PM	Passed	
52	Smoke Detector	D204	Notifier	FSP751	HU1 A Wing Cell A4	4/9/2021 1:17 PM	Passed	
53	Smoke Detector	D205	Notifier	FSP751	HU1 A Wing Cell A5	4/9/2021 1:17 PM	Passed	
54	Smoke Detector	D206	Notifier	FSP751	HU1 A Wing Cell A6	4/9/2021 1:15 PM	Passed	
55	Smoke Detector	D207	Notifier	FSP751	HU1 A Wing Cell A7	4/9/2021 1:15 PM	Passed	
56	Smoke Detector	D208	Notifier	FSP751	HU1 A Wing Cell A8	4/9/2021 1:15 PM	Passed	
57	Smoke Detector	D209	Notifier	FSP751	HU1 A Wing Cell A9	4/9/2021 1:15 PM	Passed	
58	Smoke Detector	D210	Notifier	FSP751	HU1 A Wing Cell A10	4/9/2021 1:14 PM	Passed	
59	Smoke Detector	D211	Notifier	FSP751	HU1 B Wing Cell B11	4/9/2021 1:14 PM	Passed	
60	Smoke Detector	D212	Notifier	FSP751	HU1 B Wing Cell B12	4/9/2021 1:14 PM	Passed	
61	Smoke Detector	D213	Notifier	FSP751	HU1 B Wing Cell B13	4/9/2021 1:14 PM	Passed	
62	Smoke Detector	D214	Notifier	FSP751	HU1 B Wing Cell B14	4/9/2021 1:14 PM	Passed	
63	Smoke Detector	D215	Notifier	FSP751	HU1 B Wing Cell B15	4/9/2021 1:14 PM	Passed	

Battery Results

Panel Number	Type	Parent Location	Position	Voltage	Result	Comments	Date
200	12V 8AH	1st Floor control center	Left	13.57	Passed		
200	12V 8AH	1st Floor control center	Right	13.57	Passed		

Panel Results

Number	Type	Model	Manufacturer	Location	Layout	Result	Comments	Date
200	FACP	AFP-400	Notifier	control center	1st Floor	Passed		4/9/2021 1:35 PM

NFPA72 2016 Testing and Inspection Form

Property: Nebraska Correctional Youth
Facility

Inspection Date: 4/9/2021

Property Address: 2610 North 20th Street East
omaha, ne 68124

1. PROPERTY INFORMATION

Account Name or Property Name	Nebraska Correctional Youth Facility
Shipping Street	2610 North 20th Street East
Shipping City	omaha
Shipping State/Province	ne
Shipping Zip/Postal Code	68124
Account Phone	
Main Account Email	
Authority Having Jurisdiction	
AHJ Phone Number	
Description of property	
Scope of this instance of inspection	Full

2. TESTING AND MONITORING INFORMATION

Testing Organization	
Address	
Phone	
Monitoring Organization	Local Only
Address	
Monitoring Org Phone	
Monitoring Org Email	
Monitoring Acct Number	

Phone Line one or IP

Phone Line two or IP

Means Of Transmission

3. DOCUMENTATION

Onsite location of the required record documents and site specific software

Is the location of documents and software indicated on the Component list and or layouts?

No

If the location is not indicated as YES above give description of location here

In FACP

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control unit Make and Model

4.2 Software firmware revision

4.3 System Power

The description Of Primary Power is included in the List of devices on Panels as well as the Disconnecting means location.

4.3.2 Secondary Power

The description of secondary power is included in the listing of devices and capacity is also included

5. AND 7. NOTIFICATIONS MADE BEFORE AND AFTER TESTING**NOTIFICATION MADE PRIOR AND AFTER TESTING**

Description	Time in Testing	Time off testing
Monitoring Org	8am	12:30pm
BLDG management	8am	12:30pm
BLDG occupants	8am	12:30pm
AHJ		
Other If applicable		

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

6.1 CONTROL UNIT AND RELATED EQUIPMENT

Description	Visual Inspection	Functional test	Comments
Control unit	✓	✓	
Lamps/LEDs/LCDs	✓	✓	
Fuses	✓	✓	
Trouble signals	✓	✓	
Disconnect switches	✓	✓	
Ground-fault monitoring	✓	✓	
Supervision	✓	✓	
Local annunciator	✓	✓	

Remote annunciators

Remote power panels	✓	✓
---------------------	---	---

6.2 SECONDARY POWER

6.2 Secondary Power

Description	Visual Inspection	Functional test	Comments
Battery Condition	✓	✓	
Load voltage	✓	✓	
Discharge test	✓	✓	
Charger test	✓	✓	
Remote panel batteries	✓	✓	

6.3 Alarm And Supervisory Alarm Initiating Device

Attach supplementary device test sheets for all initiating devices.

6.4 Notification Appliances

Attach supplementary appliance test sheets for all notification appliances.

6.5 Interface Equipment

Attach supplementary interface component test sheets for all interface components. Circuit Interface / Signaling Line Circuit Interface / Fire Alarm Control Interface

6.6 SUPERVISING STATION MONITORING

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	✓			
Alarm restoration	✓			
Trouble signal	✓			
Trouble restoration	✓			
Supervisory signal	✓			
Supervisory restoration	✓			

6.7 PUBLIC EMERGENCY ALARM REPORTING SYSTEM

6.7 Public Emergency Alarm Reporting System

Description	Yes	No	Time	Comments
Alarm signal		✓		NA
Alarm restoration		✓		NA
Trouble signal		✓		NA
Trouble restoration		✓		NA
Supervisory signal		✓		NA
Supervisory restoration		✓		NA

8. SYSTEM RESTORED TO NORMAL OPERATION**8. SYSTEM RESTORED TO NORMAL OPERATION**

Date and time Restored to Normal operation.

4/9/2021 12:30pm

9. CERTIFICATION

This system as specified herein has been inspected and tested according to NFPA 72, 2016 edition, Chapter 14.

Inspector Name

Date/Time

Inspector Qualifications

Phone

Company Name

10 .DEFECTS OR MALFUNCTIONS NOT CORRECTED ARE LISTED ON THE DEFICIENCIES PAGE OF THIS REPORT**10.1 ACCEPTANCE BY OWNER OR OWNER'S REPRESENTATIVE:**

The listed name below accepted the test report as specified herein:

Property Rep Auto Field

If the Auto Field is not correct who is the responsible party who is accepting the Test report?

Title:

Phone:

Date:

4/9/21