

ADDENDUM ONE RFP # 6734 Z1, QUESTIONS and ANSWERS

Date: November 16, 2022

To: All Bidders

From: Denise Schroder, Business Manager
Dept of Labor

RE: Addendum for Request for Proposal Number RFP Number 6734 Z1
to be opened December 14, 2022 at 10:00 a.m. Central Time

Questions and Answers

Following are the questions submitted and answers provided for the above mentioned Request for Proposal. The questions and answers are to be considered as part of the Request for Proposal. It is the Bidder's responsibility to check the State Purchasing Bureau website for all addenda or amendments.

Question Number	RFP Section Reference	RFP Page Number	Question	State Response
1.			Regarding the Evapco Pulse Pure System. Does the Contractor need to provide this water treatment service? If so, how many months of the year would NDOL prefer the water be tested?	No, DOL has a separate water treatment contract for services April thru October.
2.			I am assuming that the spray pump is operable for 8 months out of the year but thought I should ask?	Yes.
3.			As discussed, the building automation system (Controls) will be excluded?	Yes, controls are excluded.
4.			As discussed, the heat pump air filters are replaced by onsite engineer?	Yes.
5.			Required PM services to be performed per manufacturer's recommendations? In other words, Contractor will need to review the operational requirements per equipment manufacturer and then bid accordingly?	Yes. Yes.

This addendum will become part of the proposal and should be acknowledged with the Request for Proposal.