

**ADDENDUM TWO
QUESTIONS and ANSWERS
6755 OF**

Date: 01/20/23

To: All Bidders

From: Julie Dabydeen, Procurement Contracts Officer
AS Materiel State Purchasing Bureau (SPB)

RE: Addendum for Invitation to Bid (ITB) Number 6755 OF for LED red/white obstruction lighting system for KRNE-TV tower to be opened on January 27, 2023 at 2:00 p.m. Central Time

Following are the questions submitted and answers provided for the above-mentioned ITB. The questions and answers are to be considered as part of the ITB.

It is the Bidder's responsibility to check the SPB website for all Addenda or Amendments.

<u>Question Number</u>	<u>ITB Section Reference</u>	<u>ITB Page Number</u>	<u>Question</u>	<u>State Response</u>
1.			Are original tower drawings or a recent Structural Analysis available for review?	Please see Attachment A that is posted on the website.
2.			What power configuration is available, ie 240vac single phase, 208vac 3 phase, 480vac 3 phase (if 480vac 3 phase- Delta or & Y configuration)?	480V Delta
3.			Is there any available room for layout of equipment in shelter?	Yes, Garage and Conex container
4.			Are there any other cables or lines attached to the existing lighting conduit that would interfere with it's removal?	None that the State is aware about.
5.			What is the approximate distance from the tower to the location the new lighting controller will be mounted?	Approx. 50 ft
6.			Are any site photos available of the site including the tower, ice bridge and or shelter?	Please see Photos 1-10 that are posted on the website.

7.			We assume no night- time work is required. Please confirm.	That is Correct, only during the day.
8.			The FAA is showing the tower to be marked with red obstruction lighting. Has a new Determination been obtained changing to High Intensity lighting?	In Progress
9.			Is there cell phone coverage at the site?	Limited. but cell booster in the shelter.

This Addendum will become part of the ITB and should be acknowledged with the ITB.