

**ADDENDUM ONE
QUESTIONS and ANSWERS
6760 OF**

Date: 02/03/23

To: All Bidders

From: Julie Dabydeen, Procurement Contracts Officer
AS Materiel State Purchasing Bureau (SPB)

RE: Addendum for Invitation to Bid (ITB) Number 6760 OF for Two (2) 8x10x9 Equipment Shelters to be opened on February 10, 2023 at 2:00 p.m. Central Time

Following are the questions submitted and answers provided for the above-mentioned ITB. The questions and answers are to be considered as part of the ITB.

It is the Bidder's responsibility to check the SPB website for all Addenda or Amendments.

<u>Question Number</u>	<u>ITB Section Reference</u>	<u>ITB Page Number</u>	<u>Question</u>	<u>State Response</u>
1.			Your specification calls for "lightweight shelter with stone aggregate exterior" while our shelter is a lightweight fiberglass shelter with a molded gel coat exterior that resembles painted brick. If this alternate is acceptable, we may be able to submit a bid.	Fiberglass construction does not meet specification in ITB, see Section VI, C, 2.
2.			About the attached bid solicitation, can you please provide the need-by date of the delivered buildings?	State would consider June 1, 2023 as an acceptable need-by date.
3.			I would appreciate your assistance in getting a plan holders list for the above referenced project.	The State's vendor's list included the following: Module X Solutions Shelter Works Fibrebond Thermo Bond Buildings, LLC

This Addendum will become part of the ITB and should be acknowledged with the ITB.