

**ADDENDUM THREE
QUESTIONS and ANSWERS
6831 OF**

Date: 12-5-23

To: All Bidders

From: Brenda Sensibaugh, Procurement Contracts Officer
AS Materiel State Purchasing Bureau (SPB)

RE: Addendum for Invitation to Bid (ITB) Number 6831 OF for Multiple Controller Cabinets to be opened on December 12, 2023, at 2:00 p.m. Central Time

Following are the questions submitted and answers provided for the above-mentioned ITB. The questions and answers are to be considered as part of the ITB.

It is the Bidder's responsibility to check the SPB website for all Addenda or Amendments.

<u>Question Number</u>	<u>ITB Section Reference</u>	<u>ITB Page Number</u>	<u>Question</u>	<u>State Response</u>
1	VII	28	<p>In Section VII. A. j</p> <p>States: 'the cabinet shall be configured to allow the agency to select between 120VAC or 48VDC.'</p> <p>Q. Prior to ordering, the cabinet must be either 120VAC or 48VDC. There are several internal components that need to be included in the cabinet build. Can there be an alternate for either 120VAC or 48VDC? Since you can't have both.</p>	<p>NDOT would be willing to select a 48 VDC or 120VAC cabinet prior to ordering (they would not be configurable in NDOT's Electronic Shop), as long as both types of cabinets meet our specifications, and the supplier is willing to customize our ATC cabinet order to what NDOT needs at the time. For example: During the 1st year of the contract, NDOT may order 3 ATC cabinets for 120VAC operations and 2 for 48VDC operations. The next year we may need 6 120V ATC cabinets and 1 48VDC Cabinet.</p>

This Addendum will become part of the ITB and should be acknowledged with the ITB.

