

ADDENDUM ONE QUESTIONS and ANSWERS

Date: February 22, 2019

To: All Bidders

From: Brandy Henke, Buyer
NDOT Procurement Division

RE: Addendum for Request for Proposal Number R201-19 to be opened March 1, 2019 at 3:00 P.M. Central Time

Questions and Answers

Following are the questions submitted and answers provided for the above-mentioned Invitation to Bid. The questions and answers are to be considered as part of the Invitation to Bid. It is the Bidder's responsibility to check the State Purchasing Bureau website for all addenda or amendments.

<u>Question Number</u>	<u>Question</u>	<u>State Response</u>
1.	Am I correct in saying that you want to use acid to control pH in the range of 8.4 and 8.8?	No. The RFP is hereby amended for Section V.G.22.b: This requirement is removed.
2.	If that is so, we would need 3 pumps for the 2 tower systems. 1 for biocide, 1 for inhibitor and 1 for acid. The bid is only asking for 1.	The Cost Proposal Bid Sheet quantities are accurate and will remain as is.
3.	Also, the current listing of pot feeder says the current size. Do you want all the same size moving forward with filters or would you like to get the current sizes with filters?	Current sizes with filters.

This addendum will become part of the ITB and should be acknowledged with the Invitation to Bid response.