

# Conveyance Inspection Form

# NEBRASKA

Good Life. Great Connections.

DEPARTMENT OF LABOR

State #:

Type:

Number of Landings:

Gov/Valve Seal #:

Omaha State Office Building  
1313 Farnam Street, Rm. 233  
Omaha, NE 68102

## Inspection Fields

Using the drop-down menus below, please rate the following items as Satisfactory (SAT), Unsatisfactory (UN), or Not Applicable (N/A).

PHONE 402-595-3184 FAX 402-595-1360  
NDOL.conveyances@nebraska.gov

### Inside Car

Reopening Devices	
Leveling at Floor (+- 1/2")	
Emergency	Light
	Bell
	Phone

### Machine Room

Lighting Sufficient	
Vented	
Disconnects ML/ Lighting Lockable	
Fire Extinguisher	
Current	
Valve/Governors Sealed	

### Top of Car

Stop Sw.	
Insp. Sw.	
Light and GFCI Outlet	
HW Venting	
Safety	Handrails
	Test
Rope Cond.	Car
	Gov

### Firefighters' Service

Test	Ph. 1
	Ph. 2
Machine Room Log	

### Outside Hoistway

Door	F#
	R#
Doors P.U. Assy.	
Gib's/Retainers	

### Pit Area

Pit Ladder	
Dry Pit	
Stop	Sw. (s)
	Light
Pit Sump/Drain OK	
Pit Equip. Condition	

### Escalators

Handrail Condition	RH		Entrance/Egress End Decks		Caution Signs	Top
	LH					Bottom
Comb Plates/ Step Comb	Top		Step Skirt Clearance	RH		Step Up-Thrust Device
	Bottom			LH		

## Corrections in 30 days unless otherwise noted/Comments

Owner/Representative

Date

State Inspector

Contact Name

Phone Number

Contact Email